D. D. File No. 135-

1939

Collection No.

Mysore Residency

23/7/47 mas 13/7

Pros. Serial Nos. 1 – 31

P-66 S.N. 27 dated 23 Oct.

Subject.

Petroleum Licence

Previous References.

Later References.

D 235/40

20/8/40

S. 97.—(Blue).

MFP—1496 S&P—(M-2792)—5-5-38—100,000.

NOTES AND PRECIS.

D.2792. S.N.4

The Chief Inspector of Explosives may as usual be consulted. Draft submitted. (For a precedent please see S.N.1 and 2 of F.472-1937.).

It may be noted that the licence for the 500 gallon tank which already exists on the same site was originally granted in favour of The Asiatic Petroleum Company (India), Ltd. (Vide S.N.251 of F.330-1907.) But this company and the Burmah Oil Co., Ltd., were amalgamated in 1928 to form the Burmah-Shell Oil Storage and Distributing Co. of India Ltd. (Vide slip 'S'). After the licence is granted, the firm will be asked to furnish a certificate as provided by rule 11 of the Petroleum Rules. (For precedent please see S.N.13 of F.472-37.)

27.3.39

29.3.39.

30/3/39

S.N. 5. under issue

D.3178. S.N.6

D.3516. S.N.7

S.N.6. The application is in order. The Chief Inspector of Explosives may be consulted. Draft submitted. (For precedent please see S.N.4 to 6 of D.Dis.F.81-38 and also paras.2 to 4 of ~~offices~~ notes in that file.)

S.N.7. The application mentioned in this has to be referred to the Chief Inspector of Explosives and

and a draft has been put up which is under issue.

The P.U.C. may be filed.

8.4.39
15.

15.4.39

18435

Right.

S. No. (8) Issue.

Dy. No. 3676. S. No. (9).

Dy. No. 3896. S. No. (10).

p.w.c.1 S. No. 9.

5

S.N.8. (M)
c.1.19

The renewal endorsement on the license may kindly be signed and the office copy initialled.

Draft submitted.

p.w.c. 2. 6

S. No. 10.

at slip (G)

Please see Rule 5, Chapter VI, Part II of the Petroleum Rules.

7

A duplicate license may be granted to the firm on payment of annas eight.

K.R.N.
24/4/39.

3.5.39

4/5

S.N. 11 & 12 issue

Await

5

12

Received As.8 from Mr.R.Vanchesan, District Salesman Standard Vacuum Oil Co., Bangalore, being the fee for a duplicate petroleum licence.

Rect: 6.9.0.
22.5.39

Ah. Subr.

22.5.39

22.5.39

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
22 MAY 19
Diary No. 5202
File No. P. 135/38

5 0 65
1 1 12/5

15

D. No. 5202.

Please see S. N. 11.

Chalan for annas eight is submitted for favour of signature.

23.5.39

23.5.39

page 96 of (W)

23.5.39

Please see enclosure to S. N. 32.

A draft duplicate licence is submitted for favour of signature.

38 Papers to be closed

23.5.39.

23.5.39

15

Signed. The manager of the Local branch of the firm will call to-day for it.

25/5

Duplicate Licence Received with thanks.
R. Vanchesan
Dt. Salesman
25/5/39 Std. Vac. Co. Bangalore

8

Dy.No.11,922. S.N.(22).
Dy.No.11,923. S.N.(23).
Dy.No.12,062. S.N.(24).

22

*Pl.see Political Deptt's Notfn.No. 155-I.B, dtd. the 18th May 1939. (Copy at S.)

After the application of the British Indian Petroleum Rules, 1937, to the Civil and Military Station of Bangalore on the 18th May 1939, the Chief Inspector of Explosives, Calcutta, grants and renews licences to store petroleum in tanks in connection with a pump outfit for fuelling motor conveyances or in installations. vide rules 115 and 119 and Articles 4 & 5 of Schedule I of the rules. (These rules are also in force in the railway lands in the Mysore State over which jurisdiction has been ceded to the British Government in virtue of the Government of India's Notification No.507-I, dated the 6th Feby. 1896.) If approved the applicants may be asked to address that officer direct.

Cabinet R.

P.471 of Macpherson's, Vol.VIII, Fourth (1929) Edn. (Pub. Wks.)

Draft submitted

(Issue 22)

30.11.39

2/12/39

(Cancelled vide S.)

1.12.39

Secretary.

S.N. (25): Issue:

Dy. No. 12,585.

S.No. (26).

23.

'M'.

Please see S.Nos. 23 & 25/Cp. 378 39.

May be filed.

15.12.39.

(Cashier may issue receipt for Rs.12/-)

A

Surplus.

Dy. No. 12,745. ✓ S. No. (27). ✓ (Ack:)

Dy. No. 12,757. ✓ S. No. (28). ✓

24 Please see S. No. 25/Cf. 39. M.

S. No. 27 may be filed and S. No. 28 given to Cashier to make necessary entries in the registers maintained by him.

Sr. 20.12.38. (para 24)

Supdt. 25 → S.N. 28 should be on the file itself. No. date of receipt have been entered on the Subsidiary Cash book.

R. 20/XII/38

Dy.No.13109. S.N.(29).

26 Please see S.N.24 & 25 and para 22 of notes ante. Licences to import and store dangerous petroleum are now granted or renewed by the Chief Inspector of Explosives, Calcutta -- vide Articles 4 to 7 of Schedule I to the Petroleum Rules, 1937. The Commissioner of Police is authorized to grant licences to store upto 60 gallons of dangerous and 5,000 gallons of non-dangerous petroleum--vide Articles 2 & 3. The Commissioner was under the impression that he can grant licences even under Article 4 and the mistake has recently been pointed out to him when he asked for copies of Form K.

M. R. [illegible] 25

Under rule 128(1) fees for the grant or renewal of licences should accompany the application, which under rule 114(1) should be submitted to the licensing authority.

No action seems necessary. May be filed.

5.1.40.

5-1-40

Dy.No.1082. S.N.(30).

Please see S.N.24, 25 & 29.

From the action now taken by the Burmah-Shell Company, it appears that in reply to S.N.29, the Chief Inspector of Explosives, Calcutta, must have informed them that he renews the licences in question under the Petroleum Rules, 1937, as applied to the Civil and Military Station. This is in conformity with the view taken by office in S.N.25.

PUC is sent for information only. May be filed.

2.2.40.

2-2-40

10

Dy. No. 1576. S.N. (31).

Please see S.No. 22/25/D.D.F.135-39.
Sent for information only. May be filed.

13.2.40.

U.S. 13.2.40

Record.

CORRESPONDENCE.

STANDARD-VACUUM
MADRAS

STANDARD-VACUUM OIL COMPANY
(THE LIABILITY OF THE MEMBERS OF THE COMPANY IS LIMITED)
8/9, THAMBU CHETTY STREET
MADRAS

No.7914.

January 28, 1939.

The Secretary

to the Resident in Mysore,

Bangalore.

Dear Sir,

It is our desire to shortly apply to you for an amendment to our present license covering our Bangalore City minor petrol and kerosene oil installation. Before doing so, we will greatly appreciate it if you will advise us as to whether or not our plans for the proposed alterations should first be approved by the Chief Inspector of Explosives in India, Calcutta, or whether or not they should referred to the Chief Inspector of Mines & Explosives in Mysore, or merely referred to you direct. We will appreciate it very much if you will enlighten us on this point at your earliest convenience.

Yours truly,
STANDARD-VACUUM OIL COMPANY,

W. H. Lyn

WHL/A.

DISTRICT SALES MANAGER.

OFFICE OF THE
HON'BLE THE RESIDENT
MYSORE, BANGALORE.
Diary No. 1037
File No.

DEPARTMENT

BRANCH.

File No.

Serial No.

Draft Letter / Memorandum / Telegram DNS 135-39

Class for telegrams: Ordinary / Express * / Urgent* / Priority / Clear Line† — *Only for Foreign Telegrams. †Not for Foreign Telegrams.

No. Dated 28/1 1939

From

The Assistant Secretary.

To

The Standard-Vacuum Oil Company

8/9 Thambu Chetty Street,

MADRAS.

To be issued on	Issued on
1st Reminder	
2nd Reminder	
3rd Reminder	
Heading :	
Case or Diary No.	
If post copy of telegram required	
Date of despatch of above	
List of enclosures nil / 2	

(Code word for telegrams.)

Dear Sirs,

I am directed to refer to your letter No.7914, dated the 28th January 1939.

2. If the licence proposed to be amended was granted by this Residency, an application for the approval of the plans of the proposed alterations should be submitted to this Residency through the Commissioner of Police, Civil and Military Station, Bangalore.

Yours faithfully,

13.2.

Assistant Secretary to the Resdt.

Copy with a copy of the letter replied to is forwarded to the Commissioner of Police, Civil and Military Station, Bangalore, for information.

S. 5.

MGIPC—S1—158(Genl)MFP—(M.1933)—3-5-34—50,000 Pads.

Ref— petroleum special Warrs No. 7. 1118—34 A. O. I of 17. 12. 34, issued to the Burmah—Shell Oil Co., Madras, for storing 1000 gals., of petroleum opposite to Messrs Addison & Co., St Marks. Road, Bangalore.

No. 344/d—E1 Dated 13—2—39

Forwarded to the Secretary to the Hon'ble the Resident in Mysore, Bangalore, for favour of cancellation, as the pump and tank connected thereto have been dismantled.

R. J. Mutton
Commissioner of Police
C & M Station Bangalore.

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
15 FEB. 1939
Diary No. 1646
File No.

Filed
AJC
27/2/39.

Special License to possess dangerous petroleum (which includes acetone, wood naphtha, methyl alcohol, etc.) in one receptacle or more than one receptacle forming one unit in connection with a petrol pump outfit.

25 I

(Rule 6, Chapter IV of Part II.) oc at ps F 1118-34

No. F.1118-34 R.O. I 4-5-34. 6-5-37.

Fee Rs. 12/-

CANCELLED Secretary to the Resident in Mysore and Chief Commissioner of Coorg

License is hereby granted to Burmah-Shell Oil Storage and Distributing Company of India, Ltd., Madras for the storage in the licensed premises described below of 1,000 gallons of dangerous petroleum in a tank subject to the rules for the storage of petroleum published in notification No. 52 dated 19/7/1909 and to the further conditions as subsequently amended attached hereto.

This license shall be renewable for three years save for contravention of the provisions of the Indian Petroleum Act or the rules framed thereunder.

This license shall continue in force till the 31st December 1935

The 17th Decr. 1934

CANCELLED Secretary to the Resident in Mysore and Chief Commissioner of Coorg

for SECRETARY TO THE RESIDENT IN MYSORE.
Secretary to the Government of
or an officer appointed by the Local
Government in this behalf.

(Description of the licensed premises above referred to)

The licensed premises are situated opposite to Messrs. Addison & Co., St. Marks Road Civil and Military Station, Bangalore, and consist of a gas-tight tank of a capacity of one thousand gallons sunk underground or completely covered with earth.

~~Not applicable to this form~~

Date of renewal.	Date of expiry.	Signature of the Licensing Authority.
7th December 1935.	31st December 1936.	for SECRETARY TO THE RESIDENT IN MYSORE.
6/5/37 26th November 1936.	31st December 1937.	for SECRETARY TO THE RESIDENT IN MYSORE.
8th December 1937	31st December 1938	

CANCELLED

RESIDENT IN MYSORE AND CHIEF COMMISSIONER OF COORG

8-12-1937

S. (Agency) 72.

for Secretary to the Resident.

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum premises petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall on no account be filled from the tank or pump or from a barrel of petroleum supplied to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be stored in a gas-tight metal tank or tanks of a capacity of 1000gallons sunk completely underground or completely covered with earth above-ground when on private, leased or rented land away from public traffic in the position shown on the plan submitted and each placed in a masonry or concrete tank, the metal tank being packed round with sand, earth or clay, so that no air space is left between metal tank and masonry tank and the metal tank is not visible. Such masonry or concrete tank shall not be obligatory if the metal tank is a welded one tested up to a pressure of 3 lbs. per square inch and is buried or completely covered and is on private, leased or rented land away from public traffic.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of motor vehicles the petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of motor vehicles.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials. No subsequent change by replacements of pumps or tanks shall be effected without the previous sanction of the licensing authority. Application for such sanction shall be accompanied by plans indicating clearly such intended changes by replacements.

6. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank, before being repaired, shall be cleared of all dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the

manhole of the tank until the tank has been certified in writing to be "gas free" by a qualified chemist or engineer (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) exceeding three gallons to any unauthorised person.

10. All due precautions shall be taken for the prevention of unauthorised persons, having access to any petroleum (including acetone, wood naphtha, methyl alcohol, etc.) kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and, to the best of his ability shall prevent any other person from doing such act. The engine of any vehicle receiving petroleum from the pump shall be stopped and its lights extinguished.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use, and the conditions of this license which apply to a portable pump shall be observed. No petroleum shall be allowed above ground (except that actually in the pump) in all cases where the under ground tanks can be used in conjunction with the portable pump by making a temporary connection from the portable pump to the under ground tank.

14. In cases where portable pumps are used not more than two barrels of petroleum in reserve shall be kept within 20 feet of the pump or on public property nearby.

15. The licensee shall provide for each pump, whether kerbside or portable a minimum of two tins or drums of sand which shall be kept ready for extinguishing fires.

16. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) may be distributed between the hours of sunset and sunrise from the pump provided that the pump and any vehicle receiving petroleum from it are illuminated by electric light, or failing this by some other form of lighting, provided that no unprotected light is situated or brought within a distance of twelve feet of the pump.

MGIPC—S7—1275 (Agency) MFP—(M-2121)—11-4-34—2,000.

C N 4

Mr. W. Sd/-

No. 678/L-E 6. Dated 11-3-39.

Forwarded to the Secretary to the Hon'ble the Resident in Mysore, Bangalore, and recommended

Commissioner of Police
C & M Station Bangalore.

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
16 MAR. 1939
Diary No. 2792
File No.

D. D81/38

12600



S TO BE ADDRESSED TO THE COMPANY.

MAH-SHELL

TRIBUTING CO. OF INDIA LTD.

RPORATED IN ENGLAND)

POST BOX No 157,
BURMAH-SHELL HOUSE,
ESPLANADE,

"BURMAHSHEL".

IN REPLY PLEASE REFER TO NO T/5/A.7305

MADRAS, 6th March 1939.

Registered



The Commissioner of Police,
Civil & Military Station,
Bangalore.

Sir,

Petrol Pump No.51 - Dispensary Road,
C & M. Station, Bangalore

We have the honour to advise you that we have installed an additional 500 gallon tank at this pump site and shall therefore be obliged if you will kindly grant us an amended license for the storage of 1000 gallons.

We are advising our Dealer, Sri V.T.Padmanabha Mudaliar, Bangalore to remit to you Rs.4/- being the balance of license fee and to affix a court fee labels of As.12 to this application.

We enclose the current license for the storage of 500 gallons, specification in duplicate and plans in triplicate and shall be grateful if you will forward to us the amended license at an early date.

We have the honour to be,
Sir,
Your obedient servants,
For Burmah-Shell
Oil Storage & Distributing Co.of India Ltd.

Encl.6
MMT:VKD

Recd: Rs: 4/=
9.3.39.

Form D. O. 27.—2,000—7-'38.

BURMAH-SHELL
OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.
(Incorporated in England)
Madras Divisional Office,
MADRAS.

Specification to be attached to the application for the issue of special licence under Rule 6 Chapter IV, Part 2 of the Petroleum Act for the storage of petrol in the underground tank of petrol pump on Municipal land in Dispensary Road, Bangalore.

The Pretroleum will be stored in a gas tight mild steel tank of 500 gallons capacity and tested up to a pressure of 3 lbs per square inch, completely buried underground. The tank is on Municipal land and far away from public traffic. The tank is connected with strong metal pipes buried underground to one Shell Mex IV pump placed in the position shown in the plan herewith submitted.

Madras,
4-3-1939.

Sec Sec 6, 47

Special License to possess dangerous petroleum (which includes acetone, wood naphtha, methyl alcohol, etc.) in one receptacle or more than one receptacle forming one unit in connection with a petrol pump outfit.

(Rule 6, Chapter IV on Part II.)

D. Dis. No. F.81-38
R. O. I
11-5-37

Fee Rs. 8/-

License is hereby granted to The Burmah-Shell Oil Storage and Distributing Company of India, Limited, Madras for the storage in the licensed premises described below of 500 gallons of dangerous petroleum in a tank subject to the rules for the storage of petroleum published in notification No. 52, dated 19/7/1909 and to the further conditions as subsequently amended attached hereto.

* This license shall be renewable for three years save for contravention of the provisions of the Indian Petroleum Act or the rules framed thereunder.

This license shall continue in force till the 31st December 1939.

The 10th January 1939

for SECRETARY TO THE RESIDENT IN MYSORE.
Secretary to the Government of
or an officer appointed by the Local
Government in this behalf.

(Description of the licensed premises above referred to)

C & M Stn Banga-lore and

The licensed premises are situated at the junction of the Dispensary Road and the Main Guard Cross Road and by the side of the Indian Station Hospital, consist of a gas-tight tank of a capacity of 500 gallons sunk underground or completely covered with earth.

* Not applicable to overside outfits.

Date of renewal.	Date of expiry.	Signature of the Licensing Authority.

S. (Agency) 72.

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum premises petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall on no account be filled from the tank or pump or from a barrel of petroleum supplied to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be stored in a gas-tight metal tank or tanks of a capacity of 500 gallons sunk completely underground or completely covered with earth above-ground when on private, leased or rented land away from public traffic in the position shown on the plan submitted and each placed in a masonry or concrete tank, the metal tank being packed round with sand, earth or clay, so that no air space is left between metal tank and masonry tank and the metal tank is not visible. Such masonry or concrete tank shall not be obligatory if the metal tank is a welded one tested up to a pressure of 3 lbs. per square inch and is buried or completely covered and is on private, leased or rented land away from public traffic.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of motor vehicles the petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be–

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose, fitted with secure tap and nozzle, into the tanks of motor vehicles.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials. No subsequent change by replacements of pumps or tanks shall be effected without the previous sanction of the licensing authority. Application for such sanction shall be accompanied by plans indicating clearly such intended changes by replacements.

6. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank, before being repaired, shall be cleared of all dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the

manhole of the tank until the tank has been certified in writing to be "gas free" by a qualified chemist or engineer (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) exceeding three gallons to any unauthorised person.

10. All due precautions shall be taken for the prevention of unauthorised persons, having access to any petroleum (including acetone, wood naphtha, methyl alcohol, etc.) kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and, to the best of his ability shall prevent any other person from doing such act. The engine of any vehicle receiving petroleum from the pump shall be stopped and its lights extinguished.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use, and the conditions of this license which apply to a portable pump shall be observed. No petroleum shall be allowed above ground (except that actually in the pump) in all cases where the under ground tanks can be used in conjunction with the portable pump by making a temporary connection from the portable pump to the under ground tank.

14. In cases where portable pumps are used not more than two barrels of petroleum in reserve shall be kept within 20 feet of the pump or on public property nearby.

15. The licensee shall provide for each pump, whether kerbside or portable, a minimum of two tins or drums of sand which shall be kept ready for extinguishing fires.

16. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) may be distributed between the hours of sunset and sunrise from the pump provided that the pump and any vehicle receiving petroleum from it are illuminated by electric light, or failing this by some other form of lighting, provided that no unprotected light is situated or brought within a distance of twelve feet of the pump.

MGIPC—S6—1720 (Pol.) MFP—(M-1579)—10-1-35—2,000.

Issued 1/gmc 30.3.39

Issued 1C15 15/4/39.

D R A F T.
Letter.

D.Dis.No. F.135-39 Judl. 15th April ~~March~~

From

The Secretary to the Resident.

To

The Chief Inspector of
Explosives in India,
Calcutta.

PETROLEUM LICENCE.

Sir,

I am directed to refer to your letter No.PL.XVI-2(5), dated the 29th September 1926, regarding the grant of a petroleum licence to the Asiatic Petroleum Company (India) Ltd.

S.N.248
F.330-1907
'R'

2. I enclose a copy of a letter from the Burmah-Shell Oil Storage and Distributing Co. of India Ltd., Madras, No.T/5/A.7305, dated the 7th March 1939 with a specification and a plan in respect of an underground tank in addition to the one covered by the licence referred to above on the same site on Dispensary Road, Civil and Military Station, Bangalore. Please let me know whether a special licence for 1000 gallons can be granted to the firm under Rule 6, Chapter IV, Part II of the Bangalore Petroleum Rules.

S.N.4
c.p.6
P.U.C

× (G)

I have, etc.,

(Sd) P.M. Ramaswamy.

for Secretary to the Resident.

Copy forwarded to the Commissioner of Police, Civil and Military Station, Bangalore, for information with reference to his endorsement No.678/L., dated the 11th March 1939.

S.N.4
c.p.5
P.U.C

29.3.39 gmc 29.3.39

S. N. 6

9

MW. N. S. V

No. 1403/L-E 5 Dated 23-3-39

Forwarded to the Secretary to the
Hon'ble the Resident in Mysore, Bangalore, and recommended.

R. F. Hutton
Commissioner of Police
C & M Station Bangalore.

VL 28/3

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.

Diary No. 3178
File No. D. D 135/39

NSV (P) 16/3

TELEGRAMS:-KHALEEL, BANGALORE TELEPHONE:- 2308

MOHAMED RAHIM KHALEELI

SRI NARASIMHARAJA ROAD

BANGALORE CITY

OFFICE OF THE COMMISSIVE No. 21. MAR. 1939 BANGALORE C & M STATION

No.A.5000/39 20th March 1939
21st

The Commissioner of Police,
& M.Station,



of a Caltex Petrol Pump in
between Jeous Service station
tion - Bangalore.

No.1403/L of 8-10-1938.

ith the sanctioned and approved plan in triplicate - one original in tracing cloth and two in Blue Prints.

I also enclose herein original letters referred to above No.1403/L together with order No.R 2339/1/39 sanctioned by the - District Magistrate, C. & M.Station.

Recd: Rs: 8/=
20/3/39.

I have paid Rs.8/- as per your receipt No.A 797421 of 20-3-1939 for storing 500 gallons of Caltex Petrol.

As the capacity of the tank is 500 gallons the license requested for is for storing 500 gallons of Petrol.

I trust that you will give this your immediate attention and forward the original of the enclosed plan to the Secretary to the Hon'ble British Resident in Mysore, Bangalore, to be sent to the Chief Inspectro of Explosives Calcutta, as it is my desire to start the above service station at an early date.

The construction of the Tank and pump will be on concrete base, masonry structure all round and sand filling.

Yours faithfully,

Mohd. Rahim Khaleeli

Encls:-
MRK:NSS

OFFICE OF THE COLLEC... 7 FEB. 1939 ...

OFFICE OF THE COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION, BANGALORE.

No. 1403/L

Dated 8. 10. 1938.

FROM

J. F. B. Kaye, Esquire, I.P.
COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION,
BANGALORE.

To

Mr. Mohamed Rahim Khaleeli,
Sri Narasimharaja Road, BANGALORE CITY.

SIR,

14/10/38.

Reference: Your letter dated 2-10-1938, regarding the construction of a Petrol Bunk at the "Wells" Service Station" next to Messrs. Baccala & Company, on the South Parade, Bangalore.

I have no objection from the traffic point of view.

2. Necessary application accompanied with plan etc., should be sent for granting a licence to possess roleum.

for COMMISSIONER OF POLICE.

8/10.

HRK:FRK

No. R. 2339/1/39

244—1,000—14—8—1938

Proceedings of the Hon'ble the Resident in Mysore,

BANGALORE.

Dated.....8th.....MARCH.....193 9.

Read application dated the 6th February 1939

from Mr.Mohamed Raheem Khaleeli, submitting ~~for permission to~~ erect/re-erect Commissioner of Police' permission in original as called for and requesting sanction to erect a Caltex Petrol Bunk on South Parade as per plans already submitted.

ORDER.

SANCTIONED according to plan enclosed.

No other alterations or additions should be made. This sanction holds good for a period of one year from the date of this order.

The original of the Commissioner of Police' permission is herewith returned.

(Sd) C.F.V.WILLIAMS.

Office of the Dist. Magistrate
& Asstt. to the Resident,
C. & M. Station, Bangalore.

District Magistrate
&
Assistant to the Resident.

No.R.2339/1/38 :Enc. plan & letter. Dated. 8th March 1939.

Copy forwarded to Mr.Mohamed Raheem Khaleeli, Sri Narasimharaja road, Bangalore City, for information.

SJR.7/3

for *President, Municipal Commission.*

S.N.T

OFFICE OF THE COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION, BANGALORE.

No. 678/L. *Dated* 31—3—1939

FROM

R. S. Milton, Esquire, I.P.,

COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION,
BANGALORE.

To

The Burmah Shell Oil Storage Company,

Post Box No.157, Esplanade, MADRAS.

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
Diary No. 3516
File No. D.D. 135/39

SIRS,

Reference: Your Reminder No. T. 5. A.7305 dated 25-3-39

The application referred to, was forwarded to the Secretary to the Hon'ble the Resident in Mysore, Bangalore, under this office No.678/L dated 11-3-1939 and recommended the licence will be sent to you as soon as it is received.

R. S. Milton

COMMISSIONER OF POLICE.

31/3.

✓

Copy forwarded to the Secretary to the Hon'ble the Resident in Mysore, Bangalore, for information.

S.N.B.

Issued 21/4/39 with plan. 18/4/39 Hc

DEPARTMENT.

BRANCH.

File No.

Serial No.

Draft Letter ✓ ~~Memorandum~~ ~~Telegram~~

Class for telegrams	Ordinary / Express / Urgent* / Priority / Clear Line†	*Only for Foreign Telegrams. †Not for Foreign Telegrams.

No. R.Dis.No. F.135-39/Judl. Dated 21st April 1939

From

The Secretary to the Resident

To

The Chief Inspector of Explosives in India, Calcutta.

To be issued on	Issued on
1st Reminder	
2nd Reminder	
3rd Reminder	
Heading:	
Case or Diary No.	
If post copy of telegram required	
Date of despatch of above	
List of enclosures	

(~~Code word for telegrams.~~)

Encl. to S.N.6 ✓
P.U.C. ✓

Special licence for the storage of Petroleum.

Sir,

I am directed to forward a plan in respect of a Caltex Petrol Pump, with an underground storage tank, of 500 gallons, to be erected at No.29, South Parade (between Webbs Service Station and Wells Service Station), Bangalore. Please let me know whether a special licence may be granted ~~to the firm~~ in respect of the pump.

I have, etc.,

for Secretary to the Resident.

Copy to the Commissioner of Police, Civil and Military Station, Bangalore, for information with reference to his endorsement No.1403/L., dated the 23rd March 1939.

S.N.6 ✓
P.U.C ✓

S. 5.
MGIPC—SI—158(Genl)MFP—(M-1983)—3-5-34—50,000 Pads.

8-4-39 15-4-39

S.N.9.
(P.W.C. I)

17

Ref— Petroleum license No. 7.83—38/R.O-I Dt 2—3—38 issued to Messrs S-M-H. Ebrahim + Co'y, ~~Bangalore~~ No. 6, St Marks Road, Bangalore.

No. 396/L-E.I. Dated 5—4—39.—

Forwarded to the Secretary to the Hon'ble the Minister, Bangalore, and recommended renewal for another year. Necessary application affixed with a court fee stamp of Re—0-12—0, together with the renewal fee of Rs=12/—, has been received in this Office.

R. F. Milton
Commissioner of Police
C & M Station Bangalore.

OFFICE OF THE HON'BLE THE RESIDENT IN MYSORE, BANGALORE.
6 APR. 1939
Diary No. 3676
File No.

S.N.10.
(P.W.C.II)

STANDARD-VACUUM OIL COMPANY

(THE LIABILITY OF THE MEMBERS OF THE COMPANY IS LIMITED)

8/9, THAMBU CHETTY STREET

MADRAS

No.3769.

April 13, 1939.

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
14 APR. 19
Diary No. 3896.
File No. D.D.13?/39

S.N.32.
C.A.105
F.D.Dis.81-38(2)

LICENSE NO.F.83-38/R.C.1 D/20-12-38 FOR STORAGE OF 1000 GALLONS PETROL S.V.O.C. PETROL PUMP ON GENERAL POST OFFICE ROAD, BANGALORE CANTT.

The Resident in Mysore,
at (W)
Bangalore Cantt.

S i r,

The above petrol license, together with plan as approved by you, was misplaced recently at the time that we changed petrol dealers at this particular outlet. We will greatly appreciate it if you will be good enough to forward to us an executed duplicate copy for display in our petrol pump premises. We are not aware of the exact fee which you require for the issue of duplicate license and upon receipt of this information we will request our commission agent, Mr. Harnamdas Kapoor, to make payment on our behalf.

We have the honour to be,
S i r,
Your most obedient servants,
STANDARD-VACUUM OIL COMPANY,

W. H. Lyon

WHL/A.

DISTRICT SALES MANAGER.

Issued 10/5/39 Rs

18mc 4.5.39.

S.N.11

19

2 Drafts: Draft II.

B.Dis.No.F.135-39 Judl. Dated 6th May 1939.

From

The Asstt. Scretary.

To

The District Sales Manager,
Standard Vacuum Oil, Coy.,
8/9, Thambu Chetty Street,
Madras.

Petroleum License.

S.N.10. P.W.C. II.

Reference your letter No.3769, dated the 13th April 1939.

Please remit annas eight (in cash)* for the issue of the duplicate Petroleam license.

* Rule 1 Chapter VI Part II. (G)

Asstt. Secretary to the Resident.

KRN 24/4/39.

Hc 3.5.39.

S.N.12.

(20)

All communications should be addressed by designation and *not* by name.

D.Dis. No. F.135-39 Enc (1)
~~Exc~~ Judl.

Issued 10/5/39

FROM

The ASSISTANT SECRETARY TO THE RESIDENT IN MYSORE.

To

The Commissioner of Police,
Civil and Military Station, Bangalore.

Dated Bangalore, 10th May *1939.*

Petroleum License.

SIR,

I am directed to refer to your endorsement No.396/L, dated the 5th April 1939. Petroleum license No.F.83-38/R.O.I dated the 2nd March 1938, issued in favour of Messrs. S.M.H. Ibrahim and Company, Bangalore, is returned renewed. It may kindly be forwarded to the licencee.

I have the honour to be,

Sir,

Your most obedient servant,

p/e

ASSISTANT SECRETARY TO THE RESIDENT.

BJ

121

S.N. 13.

TELEGRAMS: "KHALEEL" TELEPHONE: No. 2308

MOHAMED RAHIM KHALEELI

SRI NARASIMHARAJA ROAD

DISTRIBUTOR IN MYSORE STATE FOR THE PRODUCTS (LUBRICANTS, ETC.) OF CALTEX (INDIA) LTD.

STOCKIST IN MYSORE STATE, BELLARY & ANANTAPUR DISTS. FOR COLOURS AND DYES OF CIBA (INDIA) LTD.

BANGALORE CITY.

May 8th 1939.

OFFICE OF THE HON'BLE THE RESIDENT IN MYSORE, BANGALORE.
9 MAY 1939
Diary No. 4755
File No. D-D 135/39.

No.A. 5278

The Manager,
The Residency Office,
Bangalore.

Dear Sir,

Subj:- License for the erection of Caltex Petrol Bunk in South Parade - Bangalore. 4666

With reference to the above I shall thank you to let me know the date on which my application and Plans were forwarded to the Chief Inspector of Explosives, Calcutta, as received from the Commissioner of Police C.&.M. Station.

X S.N. 6 (W)

Your immediate attention will be appreciated since this information is required urgently by my Principals Messrs. Caltex (India) Ltd. Madras to take up the matter with their Calcutta office for an early sanction of the License.

Yours faithfully,

Md. Rahim Khaleeli

MRK:NSS

Filed A.J.C. 16/5/39

GOVERNMENT OF INDIA.

DEPARTMENT OF EXPLOSIVES.

All communications intended for this office should be addressed to the "Chief Inspector of Explosives" and NOT to him by name.

Telegrams to "Explosives", Calcutta.

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
12 MAY 1939
Diary No. 4880
File No. A. 33/135/39

1, COUNCIL HOUSE STREET,

Dated Calcutta, the 6th May, *19* 39

No. MYS-23

FROM

The Offg: CHIEF INSPECTOR OF EXPLOSIVES IN INDIA,

To

The Secretary to the Hon'ble the
Resident in Mysore,
Bangalore.

Sub :- Petrol pump outfit of Messrs. Caltex (India) Limited at No. 29, South Parade, Bangalore.

Sir,

I have the honour to state that the plan No. nil, forwarded with your letter No.F.135-39/JUDL, dated the 21st April 1939, is approved and retained in this office for record. There appears to be no objection to the grant of a special license under Rule 6, Chapter IV, Part II of the Petroleum Rules in force in the Civil and Military Station, Bangalore and the Railway lands in Mysore to Messrs. Caltex (India) Ltd. for the above pump outfit.

I have the honour to be,

Sir,

Your most obedient servant,

Beli Ram

for Offg: Chief Inspector of Explosives in India.

Mustafi.

Issue 16.5.39.

S.N.15 Enc (1) 23

D.Dis. No. F. 135- 39/Judl. 17th May 1939.

Issued 17/5/39

For precedent please see C.f. 484 49 D.D. 81- 38

From

The Secretary to the Resident.

To

The Commissioner of Police,
Civil and Military Station,
Bangalore.

Petroleum licence.
Caltex (India) Ltd.

Sir,

S.N.6 & (W)

With reference to ~~the corresponding ending with~~ your endorsement No. 1403/L., dated the 23rd March 1939, I am directed to forward a special licence for the storage of 500 gallons of dangerous petroleum issued in favour of Mr. Mohamed Rahim Khaleeli, Sri[illegible] (Caltex-India-Ltd), Narasimharaja Road, Bangalore City, and to request that it may be transmitted to him

I have, etc.,

16.5

for Secretary to the Resident.

15.5.39.

Copy (without enclosure) forwarded for information to Mohamed Raheem Khaleeli Esq., Sri Narasimharaja Road, Bangalore City, with ref. to his letter No. A-5278, dt. 9th May 1939.

x { not to appear in the original

16.5.39 S.N.13/R.2 C

(Precedent at C.f. 49
D.Dis. 84/38)

(P)

Special License to possess dangerous petroleum (which includes acetone, wood naphtha, methyl alcohol, etc.) in one receptacle or more than one receptacle forming one unit in connection with a petrol pump outfit.

(Rule 6, Chapter IV of Part II.)

D.Dis.No. 135-39/Judl. Fee Rs. 8/-

License is hereby granted to Mr. Mohamed Rahim Khaleeli,

Sri Narasimharaja Road, Bangalore City,
(Caltex - India - Ltd)

for the storage in the licensed premises described below of 500 gallons of dangerous petroleum in a tank subject to the rules for the storage of petroleum published in notification No. 52 dated 19/7/1909 and to the further conditions attached hereto. as subsequently amended

* This license shall be renewable for Three years save for contravention of the provisions of the Indian Petroleum Act or the rules framed thereunder.

This license shall continue in force till the 31st December 1939.

16.5.39

for Secretary to the Resident in Mysore.

The 17th May 19 39

Secretary to the Government of
or an officer appointed by the Local Government in this behalf.

Seal

15.5.39. 16.5.39.

(Description of the licensed premises above referred to)

The licensed premises are situated at No. 29 South Parade, ~~between Webbs Service station and Wells service station,~~ Bangalore. and consist of a gas-tight tank of a capacity of five hundred gallons sunk underground or completely covered with earth.

~~* Not applicable to kerbside outfits.~~

Date of renewal.	Date of expiry.	Signature of the Licensing Authority.

S. (Agency) 72.

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum premises petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall on no account be filled from the tank or pump or from a barrel of petroleum supplied to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be stored in a gas-tight metal tank or tanks of a capacity of 500 gallons sunk completely underground or completely covered with earth above-ground when on private, leased or rented land away from public traffic in the position shown on the plan submitted and each placed in a masonry or concrete tank, the metal tank being packed round with sand, earth or clay, so that no air space is left between metal tank and masonry tank and the metal tank is not visible. Such masonry or concrete tank shall not be obligatory if the metal tank is a welded one tested up to a pressure of 3 lbs. per square inch and is buried or completely covered and is on private, leased or rented land away from public traffic.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of motor vehicles the petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose, fitted with secure tap and nozzle, into the tanks of motor vehicles.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials. No subsequent change by replacements of pumps or tanks shall be effected without the previous sanction of the licensing authority. Application for such sanction shall be accompanied by plans indicating clearly such intended changes by replacements.

6. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank, before being repaired, shall be cleared of all dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the

manhole of the tank until the tank has been certified in writing to be "gas free" by a qualified chemist or engineer (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) exceeding three gallons to any unauthorised person.

10. All due precautions shall be taken for the prevention of unauthorised persons, having access to any petroleum (including acetone, wood naphtha, methyl alcohol, etc.) kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and, to the best of his ability shall prevent any other person from doing such act. The engine of any vehicle receiving petroleum from the pump shall be stopped and its lights extinguished.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use, and the conditions of this license which apply to a portable pump shall be observed. No petroleum shall be allowed above ground (except that actually in the pump) in all cases where the under ground tanks can be used in conjunction with the portable pump by making a temporary connection from the portable pump to the under ground tank.

14. In cases where portable pumps are used not more than two barrels of petroleum in reserve shall be kept within 20 feet of the pump or on public property nearby.

15. The licensee shall provide for each pump, whether kerbside or portable, a minimum of two tins or drums of sand which shall be kept ready for extinguishing fires.

16. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) may be distributed between the hours of sunset and sunrise from the pump provided that the pump and any vehicle receiving petroleum from it are illuminated by electric light, or failing this by some other form of lighting, provided that no unprotected light is situated or brought within a distance of twelve feet of the pump.

MGIPC—S6—1720 (Pol.) MFP—(M-1579)—10-1-35—2,000.

S.N. 16.

26

All communications intended for this office should be addressed to the "Chief Inspector of Explosives" and NOT to him by name.

Telegrams to "Explosives", Calcutta.

GOVERNMENT OF INDIA.

DEPARTMENT OF EXPLOSIVES.

1, COUNCIL HOUSE STREET,

Dated Calcutta, the 2nd May *19* 39.

No. P.L.XVI-2(5)

OFFICE OF THE HON'BLE THE RESIDENT IN MYSORE, BANGALORE.
6 MAY 1939
Diary No. 4666
File No.

FROM

The Offg. CHIEF INSPECTOR OF EXPLOSIVES IN INDIA,

D-D 135/39.

To

The Secretary to the Hon'ble the Resident in Mysore,

BANGALORE.

Sub: Petrol pump outfit of Messrs Burmah Shell Oil Storage & Distributing Company of India Ltd., Madras, at Dispensary Road, Bangalore.

Sir,

S.N. 5-9 (11)
Ch. 8

I have the honour to state that the plan No. M 1377 forwarded with your letter No.F 135-39/Judl dated the 15th April 1939 is approved and retained in this office for record. There appears to be no objection to the grant of a special license under Rule 6, Chapter IV, Part II of the Bangalore Petroleum Rules to the Company for the storage of 1,000 gallons of dangerous petroleum in the above pump outfit.

I have the honour to be,
Sir,
Your most obedient servant,

Lt. Colonel
Offg. Chief Inspector of Explosives in India.

H.U.
2.5.39.

S.No.17 Encl(1) (2)

D.Dis. No. 135-39/Judl. 19th May 1939.

Issued. 19/5/39 B.

Issue 18/5

From

The Secretary to the Resident.

To

The Commissioner of Police,
C.&.M.Station, Bangalore,

PETROLEUM LICENCE.

Sir,

S.N.4 Cl:5. (11)

With reference to your endorsement No. 678/L - E6, dated the 11th March 1939, I am directed to forward an amended license issued in favour of the Burma-Shell Oil Storage and Distributing Company of India Ltd., Madras and to request that it may be transmitted to the firm.

I have, etc.

18/5

for Secretary to the Resident.

17.5.39.

17-5-39

Special License to possess dangerous petroleum (which includes acetone, wood naphtha, methyl alcohol, etc.) in one receptacle or more than one receptacle forming one unit in connection with a petrol pump outfit.

(Rule 6, Chapter IV of Part II.)

D.Dis. No. 135 - 39/Judl. Fee Rs. 12/-

License is hereby granted to The Burmah-Shell Oil Storage and Distributing Compnay of India, Limited, Madras, for the storage in the licensed premises described below of 1000. gallons of dangerous petroleum in a tank subject to the rules for the storage of petroleum published in notification No. 52, dated 19/7/1909 and to the further conditions attached hereto. as subsequently amended.

* This license shall be renewable for three years save for contravention of the provisions of the Indian Petroleum Act or the rules framed thereunder.

This license shall continue in force till the 31st December 1939.

The 19th May 1939

for Secretary to the Resident in Mysore.
~~Secretary to the Government of or an officer appointed by the Local Government in this behalf.~~

19.5.39

(Description of the licensed premises above referred to)

The licensed premises are situated at the junction of the Dispensary Road and the Main Guard Cross Road and by the side of the Indian Station Hospital, C.&.M. station, Bangalore and consist of a gas-tight tank of a capacity of a thousand gallons sunk underground or completely covered with earth.

* ~~Not applicable to kerbside outfits.~~

Date of renewal.	Date of expiry.	Signature of the Licensing Authority.

S. (Agency) 72.

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum premises petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall on no account be filled from the tank or pump or from a barrel of petroleum supplied to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be stored in a gas-tight metal tank or tanks of a capacity of 1000 gallons sunk completely underground or completely covered with earth above-ground when on private, leased or rented land away from public traffic in the position shown on the plan submitted and each placed in a masonry or concrete tank, the metal tank being packed round with sand, earth or clay, so that no air space is left between metal tank and masonry tank and the metal tank is not visible. Such masonry or concrete tank shall not be obligatory if the metal tank is a welded one tested up to a pressure of 3 lbs. per square inch and is buried or completely covered and is on private, leased or rented land away from public traffic.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of motor vehicles the petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of motor vehicles, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose, fitted with secure tap and nozzle, into the tanks of motor vehicles.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials. No subsequent change by replacements of pumps or tanks shall be effected without the previous sanction of the licensing authority. Application for such sanction shall be accompanied by plans indicating clearly such intended changes by replacements.

6. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) shall enter the tank "under seal;" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank, before being repaired, shall be cleared of all dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the

S.No.17 Encl(1) 2

D.Dis. No. 135-39/Judl. 19th May 1939.

Issued. 19/5/39

From

The Secretary to the Resident.

To

The Commissioner of Police,
C.&.M.Station, Bangalore,

PETROLEUM LICENCE.

Sir,

S.N.4 Cl:5.

With reference to your endorsement No. 678/L - E6, dated the 11th March 1939, I am directed to forward an amended license issued in favour of the Burma-Shell Oil Storage and Distributing Company of India Ltd., Madras and to request that it may be transmitted to the firm.

I have, etc

for Secretary to the Resident.

17.5.39.

manhole of the tank until the tank has been certified in writing to be "gas free" by a qualified chemist or engineer (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) exceeding three gallons to any unauthorised person.

10. All due precautions shall be taken for the prevention of unauthorised persons, having access to any petroleum (including acetone, wood naphtha, methyl alcohol, etc.) kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and, to the best of his ability shall prevent any other person from doing such act. The engine of any vehicle receiving petroleum from the pump shall be stopped and its lights extinguished.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use, and the conditions of this license which apply to a portable pump shall be observed. No petroleum shall be allowed above ground (except that actually in the pump) in all cases where the under ground tanks can be used in conjunction with the portable pump by making a temporary connection from the portable pump to the under ground tank.

14. In cases where portable pumps are used not more than two barrels of petroleum in reserve shall be kept within 20 feet of the pump or on public property nearby.

15. The licensee shall provide for each pump, whether kerbside or portable, a minimum of two tins or drums of sand which shall be kept ready for extinguishing fires.

16. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) may be distributed between the hours of sunset and sunrise from the pump provided that the pump and any vehicle receiving petroleum from it are illuminated by electric light, or failing this by some other form of lighting, provided that no unprotected light is situated or brought within a distance of twelve feet of the pump.

MGIPC—S6—1720 (Pol.) MFP—(M-1579)—10-1-35—2,000.

31

S.N.18

Mr. Silvera

TELEGRAMS: "KHALEEL" TELEPHONE: No. 2308

MOHAMED RAHIM KHALEELI

SRI NARASIMHARAJA ROAD

DISTRIBUTOR IN MYSORE STATE FOR THE PRODUCTS (LUBRICANTS, ETC.) OF CALTEX (INDIA) LTD.

STOCKIST IN MYSORE STATE, BELLARY & ANANTAPUR DISTS. FOR COLOURS AND DYES OF CIBA (INDIA) LTD.

BANGALORE CITY.

May 13th 1939.

OFFICE OF THE
RESIDENT
IN MYSORE, BANGALORE.
16 MAY
Diary No. 5023
File No.
DD 1357/39

No.A.5315

The Manager,
Resident's office,
Bangalore.

Dear Sir,

Subj:- License for erecting Caltex Petrol Pump in South Parade -Bangalore.

S.N.13 2(M) I invite your kind attention to my letter No.A.5278 of May 8th 1939 reference above and shall thank you to please advise me per return the date on which the papers were forwarded to Chief Inspector of Explosives, Calcutta.

Please treat this as urgent and important.

Yours faithfully,

Mohd. Rahim Khaleeli

MRK/NSS

Filed
A/C.
23/5/39

manhole of the tank until the tank has been certified in writing to be "gas free" by a qualified chemist or engineer (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum (including acetone, wood naphtha, methyl alcohol, etc.) exceeding three gallons to any unauthorised person.

10. All due precautions shall be taken for the prevention of unauthorised persons, having access to any petroleum (including acetone, wood naphtha, methyl alcohol, etc.) kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and, to the best of his ability shall prevent any other person from doing such act. The engine of any vehicle receiving petroleum from the pump shall be stopped and its lights extinguished.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use, and the conditions of this license which apply to a portable pump shall be observed. No petroleum shall be allowed above ground (except that actually in the pump) in all cases where the under ground tanks can be used in conjunction with the portable pump by making a temporary connection from the portable pump to the under ground tank.

14. In cases where portable pumps are used not more than two barrels of petroleum in reserve shall be kept within 20 feet of the pump or on public property nearby.

15. The licensee shall provide for each pump, whether kerbside or portable, a minimum of two tins or drums of sand which shall be kept ready for extinguishing fires.

16. The petroleum (including acetone, wood naphtha, methyl alcohol, etc.) may be distributed between the hours of sunset and sunrise from the pump provided that the pump and any vehicle receiving petroleum from it are illuminated by electric light, or failing this by some other form of lighting, provided that no unprotected light is situated or brought within a distance of twelve feet of the pump.

MGIPC—S6—1720 (Pol.) MFP—(M-1579)—10-1-35—2,000.

32

S. N. 19

STANDARD-VACUUM OIL COMPANY

(THE LIABILITY OF THE MEMBERS OF THE COMPANY IS LIMITED)

8/9, THAMBU CHETTY STREET

MADRAS

No.6192

May 15, 1939.

PETROLEUM LICENSE.

The Assistant Secretary

to The Honorable the Resident in Mysore,

Bangalore City.

S i r,

We thank you for your D.EIS.No.F.135/39 G.U.T.L. of the 11th of May.

We have requested our District Salesman Mr.R.Vanchesan to call on your office and pay to you in cash the requisite fee in the sum of Re.0-8-0 only for the issue of a duplicate Petroleum License for the Socony petrol pump on General Post Office Road, Bangalore Cantonment.

OFFICE OF THE
... RESIDENT
IN MYSORE, BANGALORE.
17 MAY 1939
Diary No. 5065
File No. 020/135/39

We have the honourto be,
S i r,
Your most obedient servants,
STANDARD-VACUUM OIL COMPANY,

ASST. MANAGER.

WHL/P.

CROWN TRIPLICATE. No. 585

Chalan for payment of money into the Imperial Bank of India, Bangalore.

Chalan No. 1405 — Monthly consecutive number assigned to the credit in the day-book.

RESIDENT'S TREASURY BANGALORE 23 MAY 1939

By whom paid.	On what account.	Amount. Rs.	a.	p.	Head to which the amount should be Credited.
By the Assistant Secretary to the Hon'ble the Resident in Mysore.	Being the fee realised under the ~~Indian Arms Rules from~~ Petroleum rules from Mr. R. VanChesan District Salesman, Standard Vacuum oil Co., Bangalore.		8	—	~~M.A.T. Police—Cash Receipts under the Arms Act.~~ Misc. Fees & Fines & forfeitures
	Total ...	—	8	—	

Total in words ~~Rs.~~ annas eight only

Bangalore, 23rd May 1939. Assistant Secretary to the Resident.

IMPERIAL BANK OF INDIA BANGALORE CASH RECEIVED 23 MAY 1939

THE HON'BLE THE RESIDENT'S TREASURY, BANGALORE.

Entered correct. Chalan Clerk.

Head Acctt. Try. Asst. T. O. 23/5

SPACE FOR USE BY THE IMPERIAL BANK OF INDIA, BANGALORE.

RECEIVED Rs. AS. 8 PS. (RUPEES ~~nil~~ eight only)

FOR IMPERIAL BANK OF INDIA.

Shroff. Cashier. Agent, Imperial Bank of India, Bangalore.

p. Agent, Bangalore

AMEENA BAI
(MRS. AHMED SAIT.)
LAND LADY

S.N.20

28. PARK ROAD.
TASKER TOWN.

34

BANGALORE 10th. SEPT 1939.

The Secretary,
To The Hon'ble The British Resident
In Mysore., - BANGALORE.

Most Respected Sir,

Subject:- Petrol Pump Outfit of Messrs CALTEX (India) Ltd., at No. 29. South Parade, Bangalore Erected by Mr. Mohomed Raheem Khaleeli.

I most respectfully beg to inform you that I am the owner of the above land, which I have leased to Mr. Raheem Khaleeli, of office at Sri Narasimharaja Road, Bangalore City whereon the above referred Petrol Bunk is erected by Mr. Md: Raheem Khaleeli for Messrs Caltex Ltd.,

As the date of your sanction is to be inserted in the lease deed I shall feel much obliged by your kindly informing me, at your very early convenience, the date on which the sanction was accorded for the same to Md. Raheem Khaleeli.

Thanking you much in anticipation,

I respectfully beg to Remain,

yours truly.

Ameena Bai A.H.S.

(Daughter of the late Haji Sir Ismail Sait Kt.)

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
11 SEP 1939
9459.
Diary No.....
File No. 129/135/39.

S.N.21

35

DEPARTMENT.

BRANCH.

File No.

Serial No.

Issued 25/9/39 Issue 2219

Draft Letter / Memorandum / Telegram

INLAND: Immediate / Important / Express / Ordinary

FOREIGN: Immediate / Important / Ordinary / Without priority

Class for telegrams

D.Dis. No. F.135-39 Judl. Dated 19

From The Asst.Secy. to the Resdt

To

Mrs. Ahmed Sait.
Land Lady,
28, Park Road
Tasker Town
Bangalore.

To be issued on

Issued on

1st Reminder

2nd Reminder

3rd Reminder

Heading:

Case or Diary No.

If post copy of telegram required S.N.20 p.u.c.

Date of despatch of above

List of enclosures

(Code word for telegrams.)

Encl.to
S.N.15
c.p.24-25
M

Reference your letter dated the 10th September 1939.

2. A licence for the storage of dangerous 500 gallons of petroleum was issued in favour of Mr.Mohamed Rahim Khaleel, ~~Sri Narasimharaja Road, Bangalore City~~ on the 17th May 1939, under D.Dis. F. No.135-39/Judl.

22.9.

ASST.SECY. TO THE RESDT.

Typed 23/9

20/9/39

21.9.39

S. 5.
M?IPC—S5—1595(S&P)?IF?—(M 944)—6-3-39—60,000 Pads.

S:122 (

STANDARD-VACUUM OIL COMPANY

(THE LIABILITY OF THE MEMBERS OF THE COMPANY IS LIMITED)

UNITED INDIA BUILDING

ESPLANADE

MADRAS

Presented in person by Mr. Harnamdas Kapoor. (Tasker Town, Bangalore)
Mr. BR
24.11.39

No.1330

Nov. 22, 1939.

Mr. Usman
17 135/37

APPLICATION FOR STORAGE LICENSE
~~ADDITIONAL TANKAGE~~
BANGALORE CITY INSTALLATION.

HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
25 NOV 1939
Diary No. 11,922
File No.

Recd 27.11.39

The Hon'ble Resident,

in Mysore State,

Bangalore.

Sir,

We have the honour to attach hereto our application in Form D for a license for the storage of 14,531 Imperial gallons of dangerous petroleum in our Bangalore City Installation. For your information, the tank in question is shown on the attached Plan No.A-115 as tank No.3 which is currently being used for mixing purposes in effecting the power alcohol petrol blend, as required by the Mysore Government. We will greatly appreciate it if you will arrange to expedite the issuance of the requested license at your earliest convenience.

x Oil-Statistics 24, Cont.

By copy of this letter, we are requesting our Bangalore Agent, Mr. Harnamdas Kapoor, to arrange to pay to you such fees as may be prescribed for the issuance of the above requested license.

We have the honour to be,
Sir,
Your most obedient servants,
STANDARD-VACUUM OIL COMPANY,

C. Larson

DISTRICT SALES MANAGER.

Enclos:
WHL:V.

The Western India Oil Distributing Co. Ltd.

TELEGRAMS: "WESTOILSCO."

TELEPHONE No. 2350

CODES USED: BENTLEY'S & PRIVATE.

P. & O. BANK BUILDING,
ARMENIAN STREET,
P. O. Box No. 27,

Madras 23rd Novr. 1939

Ref. No. S.3100.

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
25 NOV. 1939
Diary No. 11,923.
File No.

To,

The Secretary,
To The Resident in Mysore,
Civil & Military Station,
Bangalore.

Sir,

We beg to enclose herewith License No. D.Dis.F.8138/R.O.1 dated 19-8-38, in respect of the Petrol Pump Outfit on the Dispensary Road, Civil & Military Station, Bangalore, and shall be much obliged if you will please return the same to us, duly renewed for a further period of one year from 1-1-1940 to 31-12-1940.

We also enclose herewith our cheque for Rs.12/- being the fee payable in respect of the above license and shall be pleased to have your formal receipt for the same, as it is required for audit purposes.

Thanking you,

We have the honour to be,

Sir,

Your most obedient servants,
FOR THE WESTERN INDIA OIL DISG.CO.LTD.

Mg. Agents.

Enc: No.190384

PRS:KC.

All Quotations are without Engagement.

ALL COMMUNICATIONS TO BE ADDRESSED TO THE COMPANY.

TELEPHONE No. 26231 (10 LINES.)
POST BOX No. 193.

TELEGRAPHIC ADDRESS:
"BURMAHSHEL."

"DC" **BURMAH-SHELL**

OIL STORAGE & DISTRIBUTING CO., OF INDIA, LTD.,

(INCORPORATED IN ENGLAND.)

BURMAH-SHELL HOUSE,
BOMBAY, 22nd November 1939.

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
29 NOV. 1939
Diary No. 12,062
File No.

IN REPLY PLEASE REFER TO NO A/B.15/1.

REGISTERED & INSURED.

The Secretary to the Resident in Mysore &
Chief Commissioner of Coorg.
B A N G A L O R E.

Sir,

Renewal of Licenses for 1940 in respect of
Dangerous Petroleum at Birur.

We have the honour to enclose 2 applications in form 'D' together with the undernoted two licenses for our Petrol Depot at Birur, due for renewal for the year 1940 :-

License No.	Date.	Form.	Dangerous Petroleum Bulk.	Dangerous Petroleum Not in Bulk.	License Fee.
(1) F.81-38 R.O.I.	17-12-38	Special license	10000		Rs.52/-.
(2) -do-	-do-	'B'		1000	

We are sending herewith Rs.52/8/- (Rupees fiftytwo & annas eight only) Rs.52/- on account of license fee and Rs. 0-8-0 to meet the cost of Court Fee Stamp.

We shall be obliged if you will kindly return the licenses duly renewed for the year 1940 at your early convenience.

We have the honour to be,
Sir,
Your most obedient servants,
FOR BURMAH-SHELL OIL STORAGE &
DISTRIBUTING CO. OF INDIA LTD.

Enclo: 2 Applications in form 'D'
2 Licenses & Rs.52/8/-

DKV/N.

E 7125

39

DEPARTMENT.

BRANCH.

File No.

Serial No.

Issue 2/12

Issued 11/12/39

Draft Letter / Memorandum / Telegram

Enc. 6 No. 3 Rs 52-8-0 sent by insured post

D.Dis.No.F.135-39
Judl.

Dated 11th Decr. 1939.

Class for telegrams	INLAND:	FOREIGN:
	Immediate / Important / Express / Ordinary	Immediate / Important / Ordinary / Without priority

No.

From The Secretary to the Resident.

To

Mr. Harnamdas Kapoor,
Agent, Standard-Vacuum
Oil Company, Tasker Town,
Bangalore.

The Managing Agents, The
Western India Oil Distri-
buting Co.Ltd., P & O Bank
Building, Armenian Street,
P.O.Box No.27, Madras.

Messrs. Burmah-Shell Oil
Storage & Distributing Co.
of India, Ltd., Burmah-
Shell House, Ballard Estate
,Bombay.

To be issued on	Issued on
1st Reminder	
2nd Reminder	
3rd Reminder	
Heading:	
Case or Diary No.	
If post copy of telegram required	
Date of despatch of above	
List of enclosures	

(Code word for telegrams.)

Petroleum licences.

Sir/Sirs,

I am directed to refer to

Sno.22
Sno.23 (Pac.)
Sno.24

letter from the District Sales Manager, Standard-Vacuum Oil Company,

---

your letter

No.1330, dated the 22nd Nov, 1939

Ref.No.G.3100, dated the 23/11/1939

No.A/B.15/1, dtd. the 22/11/1939.

2. From the 18th May 1939 the British Indian Petroleum Rules, 1937, have been ~~applied to~~ put into force in the Civil and Military Station of Bangalore and the railway lands in the

S. 5.
MGIPC—S5—1595(S&P)MFP—(M-944)—6-3-39—60,000 Pads.

Mysore State ~~xxxx xhixh~~ under British jurisdiction, and the Chief Inpsector of Explosives, Calcutta, grants or renews licences to store petroleum in tanks in connection with a pump outfit for fuelling motor conveyances or in installations. Will you please therefore address that officer direct ?

3. The enclosures to ~~xxxx~~ the letter under reference are returned. Please acknowledge receipt.

I have etc.

Sd/. P. M. Raman Nayar,

for Secretary to the Resident.

30.11.38.

* (with the cheque for Rs 12/-)
* [with Rs. 52/8/-]

* to No. (2).
* to No. (3).

SW 26.

The Western India Oil Distributing Co. Ltd.

TELEGRAMS: "WESTOILSCO."

TELEPHONE NO. 2350

CODES USED: BENTLEY'S & PRIVATE.

P. & O. BANK BUILDING,
ARMENIAN STREET,
P. O. Box No. 27,.

Madras 12th Decr. 1939

Ref. No. S. 3538

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
13 DEC. 1939
Diary No. 12,585
File No.

To,

The Secretary,
To The Hon'ble The Resident in Mysore,
Bangalore.

Sir,

PETROLEUM LICENSE.

We beg to acknowledge the receipt of your letter No. D.Dis. No.F.135-39/Judl. dated the 11th inst., together with the enclosures referred to therein, for which we thank you.

As directed by your goodself, we are sending our application to the Chief Inspector of Explosives in India, Calcutta, for renewal of the license.

Thanking you,

We have the honour to be,

Sir,

Your most obedient servants,
FOR THE WESTERN INDIA OIL DISTG.CO.LTD.,

Mg. Agents.

PRS:KC.

All Quotations are without Engagement.

S.N. 28.

A/cs. 9, 100 Bks., 100x3, 5-39.

No. 8326

BURMAH-SHELL

OIL STORAGE & DISTRIBUTING CO., OF INDIA, LTD.
(INCORPORATED IN ENGLAND.)

ACCOUNT No.

Bombay, 13-12-193[illegible]

Bill Reference	Rs.	As.	Ps.
G. Insurance Cl.			
	10		
	20		
Total Rs....	52		

Received from the Secretary to the Resident in Mysore, Bangalore
the sum of Rupees Fifty two only
Way No 12757 by G. Mathew Nicholas.
File No..... FOR "BURMAH-SHELL"
OIL STORAGE & DISTRIBUTING CO., OF INDIA, LTD.

INDIA REVENUE ONE ANNA

Old R. & P.-4.

Acknowledgment.

(To be returned to office of posting for delivery to sender.)

RECEIVED a registered* for Rs.60/- No. [illegible]
addressed to (name) Messrs. Burma-Shell Oil Storage and Distributing Co., of India, Ltd. Burma-Shell House, Ballard Estate, Bombay.

† Insured for Rs. Rs 60/-
† Weighing (*in words*) Fifty Five
Signature of addressee FOR BURMAH-SHELL OIL STORAGE & DISTRIBUTING CO., OF INDIA, LTD.
Date of delivery 19 13/12/39

* Strike out "letter," "post-card," "packet," or "parcel," as the case may be, preceded by the word "insured" if the article is insured.
† To be filled up only in the case of insured articles, and to be scored out in the case of other articles.

Lal Chand & Sons, Printers, Calcutta—No. 5467B (A.358)—12-9-38—20,000 Bks.

T. 14. 250 Pkts., x 500, 10-39.

COPY.

BURMAH-SHELL, BOMBAY.

"DC"

A/B.3/6.

REGISTERED. 21st December 39.

The Chief Inspector of Explosives in India,
1 Council House Street,
C A L C U T T A.

S i r,

Renewal of Licenses for the year 1940 for the storage of Petroleum in respect of Depots at Arsikere, Birur & Davangere.

We have the honour to send herewith copies of the following letters received in reply to our applications for renewal of licenses for the year 1940 for the storage of petroleum at our Depots mentioned below :-

Copy of letter (1) No.2215/L.39 of 4-12-39 from the Commissioner of Police, Civil & Military Station, Bangalore.

(2) D.Dis.No.F.135-39/Jud.L of 11-12-39 from the Secretary to the Hon'ble the Resident in Mysore

Depots under reference:-

Station.	Depot.	License for 1939.	Licensed Capacity in Gallons. Bulk.	Packed.	Total.	Nature of Petroleum.	Existing Licensing Authority.
Arsikere	A	No.9/E	6714	9286	16000	Non-Dangerous.	a) The Commissioner of Police, Civil & Military Station, Bangalore.
"	B	8/E	10000	9000	19000	"	
Birur	A	7/E	8500	11500	20000	"	
"	B	6/E	7500	11680	19180	"	
Davangere	A	5/E	8500	9120	17620	"	
"	B	4/E	5000	11000	16000	"	

T. 14, 250 Pkts., x 500, 10-39.

COPY.

Station.	Depot.	License for 1939	Licensed Capacity in Gallons. Bulk.	Packed.	Total.	Nature of Petroleum.	Existing Licensing Authority.
Birur	Benzine	(1) M81-38 R.OI.	10000		10000	Dangerous.	(b) The Secy. to the Hon'ble the Resident in Mysore and Chief Commissioner of Coorg Bangalore.
		(2) "		1000	1000	"	

All the above Depots are on Rly. lands which from 1-1-38 have been taken over by the Mysore State Railway from the M.& S.M.Ry.

It will be noticed that whereas the authority marked (a) above has only asked us to pay the additional license fee on the basis of the scale provided under the New Petroleum Rules 1937, the authority marked (b) has refunded us the renewal fee paid by us and has directed us to apply to you for renewal of the licenses hitherto renewed by him. In regard to the station "Birur", it seems unlikely to us that under the Petroleum Rules 1937 there could be two separate Licensing Authorities to grant/renew licenses:- (1) one for non-dangerous petroleum (2) the other for dangerous petroleum. We shall be obliged if you will kindly advise us

(1) whether we shall be in order in applying to you for renewal of Birur Benzine Depot licenses only or of licenses for all the Depots referred to above

(2) to whom the license fee should be paid? Would it be in order for us to remit to you the license fee for the year 1940 for Birur Benzine Depot licenses only and the balance of license fee in respect of the remaining Depots to the Commissioner of Police.

T. 14, 250 Pkts., x 500, 10-39.

COPY.

BURMAH-SHELL, BOMBAY.

Civil & Military Station, Bangalore as required by this authority.

We shall be grateful for an early reply.

We have the honour to be,
S i r,
Your most obedient servants,
FOR BURMAH-SHELL OIL STORAGE & DISTRIBUTING CO.OF INDIA LTD.

G. Mukerji

Enclo. 2 Copies of letters.

GKV/PVE.

Copy to the Secretary to the Hon'ble the Resident in Mysore, Bangalore, with compliments.

G. Mukerji

BS 135/39

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
25 DEC. 1939
Diary No. 13109
File No. BS 135/39

T.-14; 250 Pkts., x 500, 10-39.

COPY.

BURMAH-SHELL, BOMBAY.

COPY.

MEMO.

FROM

THE COMMISSIONER OF POLICE,
CIVIL AND MILITARY STATION,
BANGALORE

To

The Burmah-Shell Oil Storage Company Limited, Ballard Estate, BOMBAY.

Reference No:- 2215/L.39 Bangalore, Dated 4/XII- 1939.

Sirs,

Reference: Your letter No.A-3.15/1 dated 22nd November 1939.

As per the new Petroleum Rules, 1937, the following fees should be paid :-

Installation at	Arsikere	for 16,000	gallons ...	79
"	"	19,000	" ...	94
"	Birur	20,000	" ...	99
"	"	19,180	" ...	99
"	Davangere	17,620	" ...	89
"		16,000	" ...	79
				539

As you have paid Rs.440/8/-, a further sum of Rs.98/8/- may be sent.

2. 3 copies each of plan drawn to scale of each Installation showing its position etc may also be sent.

Sd/-.

COMMISSIONER OF POLICE.

P.M?

T. 14, 250 Pkts., x 500/10-39.

COPY. 8N30

BURMAH-SHELL, BOMBAY. 48

"DO"

OFFICE OF THE
HON'BLE THE RESIDENT
IN MYSORE, BANGALORE.
27 JAN. 1940
Diary No. 1082
File No.

BE 135/39
1/2.

A/B.3/6

REGISTERED. 24th January 1940.

The Chief Inspector of Explosives in India,
1 Council House Street,
C A L C U T T A.

S i r,

Renewal of Licenses for the year 1940
for the storage of Petroleum in respect
of Depots at Arsikere, Birur & Davangere.

We have the honour to acknowledge with thanks receipt of your letter No.G-40(1)5 Mysore of the 15th instant and enclose, as required, seven applications in form 'D' with plans in triplicate in respect of the following Depots :-

Station	Depot.	Licence for 1939.	Licensed Capacity in Gallons. Bulk.	Packed.	Total.	Nature of Petroleum.	Licence Fee. Rs.a.p.
Arsikere	A	9/E	6714	9286	16000	Non-Dangerous.	79-0-0
-do-	B	8/E	10000	9000	19000	-do-	94-0-0
Birur	A	7/E	8500	11500	20000	-do-	99-0-0
-do-	B	6/E	7500	11680	19180	-do-	99-0-0
Davangere	A	5/E	8500	9120	17620	-do-	89-0-0
-do-	B	4/E	5000	11000	16000	-do-	79-0-0
Birur	Benzine	(1) E81-38 R.O.I.	10000	-	10000)		
-do-	"	(2) "		1000	1000)	Dangerous	54-0-0
						Total.	593-0-0

T. 14, 250 Pkts., x-500, 10-39.

COPY.

BURMAH-SHELL, BOMBAY.

Original Licenses for 1939 in respect of Non-Dangerous Petroleum at Arsikere, Birur & Davangere.

We shall forward these licences to you as soon as they are returned to us by the Commissioner of Police, Civil & Military Station, Bangalore, to whom we have written in this connection as per copy of our letter of date attached.

Original Licenses in respect of Dangerous Petroleum at Birur.

The two licences referred to above are sent herewith as required. A combined licence in form 'L' may please be issued to us in respect of this Depot

We have requested our Calcutta Branch Office to pay you the necessary licence fee and shall be obliged if you will kindly issue us licences for the year 1940 together with their authenticated copies at your early convenience.

We have the honour to be,
S i r,
Your most obedient servants,
FOR BURMAH-SHELL OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.
(Sd.) G. V. THATTEY.

Enclos.
(1) 7 Applications in form 'D' with plans in triplicate.
(2) 2 Licences for Birur Benzine Depot.
(3) Copy of letter.

GVKV/PVE.

Copy to the Secretary to the Hon'ble the Resident in Mysore, Bangalore, with compliments.

Copy to The Honorable The Resident in Mysore, Bangalore.



Application for [illegible] Licence
[illegible]
Railway [illegible] Bangalore City.

The Chief Inspector of Explosives in India,
1, Council house street,
Calcutta.

S i r,

We have the honour to attach hereto our application in Form D for license to store 39456 gallons of dangerous petroleum in our Bangalore city installation which is situated on the Railway grounds. Heretobefore licenses for this storage have been received from the Honorable the Resident in Mysore and we are now advised that effective as of May last the licensing authority for dangerous petroleum on Railway lands in Mysore state lies with your office. A clarification of this point has delayed our formal application for a new license from you.

You will note from the attached tracing and plans that we now have one storage tank for pure petrol of 15000 gallons and one 15000 gallon tank for the storage of blended petrol/alcohol for supply to Bangalore city pumps. An additional 10000 gallon tank is in operation for the storage of pure alcohol. We are also requesting a license for overhead measuring tank of a capacity of 300 gallons which we propose to install on receipt of your authorization. This measuring tank is for the purpose of accurately measuring quantities of pure petrol and pure alcohol pumped into the blending tank to enable us to effect a blend along the lines prescribed under the Mysore Alcohol/Petrol Rules etc. We would appreciate it if, in forwarding a license for the storage, you will be good enough to approve this proposal to erect such measuring tank.

As instructed by the Honorable the Resident in Mysore, our application for storage licenses of our kerosene godowns and tanks are now pending with the Police Commissioner, [illegible] Station, Bangalore.

We are arranging for our Calcutta office to pay to you the sum of Rs.199/- as fee for the requisite licence.

We have the honour to be,
S i r,
Your most obedient servants,
STANDARD-VACUUM OIL COMPANY,
(Sd.) W. H LYON
DISTRICT MANAGER.

WHL/P.